

CUSTOMER SERVICE INSPECTION CERTIFICATION

Name of PWS: Lavon Water Supply Corporation
PWS I.D. # 0430037
Location of Service: _____

Reason for Inspection: New construction
Existing service where contaminant hazards are suspected
Major renovation or expansion of distribution facilities.

I _____, upon inspection of the private plumbing facilities connected to the Lavon Water Supply Corporation public water supply do hereby certify that, to the best of my knowledge:

1. No direct connection between the public drinking water supply and a potential source of contamination exists. Potential sources of contamination are isolated from the public water system by an air gap or an appropriate backflow prevention assembly in accordance with state plumbing regulations. Additionally, all pressure relief valves and thermal expansion devices are in compliance with state plumbing codes. **Compliance / Non-Compliance**
2. No cross-connection between the public drinking water supply and a private system exists. Where an actual air gap is not maintained between the public water supply and a private water supply, an approved reduced pressure-zone backflow prevention assembly is properly installed and a service agreement exists for annual inspection and testing by a certified backflow prevention device tester. **Compliance / Non-Compliance**
3. No connection exists which would allow the return of water used for condensing, cooling, or industrial processes back to the public water supply. **Compliance / Non-Compliance**
4. No pipe or pipe fitting which contains more than 8.0% lead exists in private plumbing facilities installed on or after July 1, 1988. **Compliance / Non-Compliance**
5. No solder or flux which contains more than 0.2% lead exists in private plumbing facilities installed on or after July 1, 1988. **Compliance / Non-Compliance**
6. No plumbing fixture is installed which is not in compliance with a state approved plumbing code. **Compliance / Non-Compliance**

Water service shall not be provided or restored to the private plumbing facilities until the above conditions are determined to be in compliance.

I further certify that the following materials were used in the installation of the plumbing facilities:
Circle the one that applies:

Service Lines: Lead Copper PVC Other: _____
Solder: Lead Lead Free Solvent Weld Other: _____

I recognize that this document shall become a permanent record of the Lavon Water Supply Corporation and that I am legally responsible for the validity of the information I have provided.

Signature of Inspector

Registration Number

Title

Type of Registration

Date